## SPECIAL TERMS AND CONDITIONS

1. Application Number: 02 43 16 0174 B001

2. Facility Name: Ohio Rubber Company

Willoughby, Ohio

3. Company ID: No. 4 Boiler

4. Equipment Description: B & W Model 243-25 Coal Boiler

## 5. Special Terms and Conditions:

- a. A smoke density meter with recorder shall be installed and maintained on the Babcock and Wilcox coal fired boiler (Company ID No. 4 Boiler). The monitoring equipment shall be operated at all times when the boiler is in operation. The Permit holder shall keep records of the emissions on file at the plant for at least twenty-four (24) months, and shall make such records available to the Ohio Environmental Protection Agency upon request. The smoke density meter is to be calibrated annually.
- b. Any oxygen analyzer with recorder shall be installed and maintained on the Babcock and Wilcox coal fired boiler (Company ID No. 4 Boiler). The oxygen analyzer shall be operated at all times when the boiler is in operation. The Permit holder shall keep records from the combustion monitoring equipment on file at the plant for at least twenty-four (24) months, and shall make such records available to the Ohio Environmental Protection Agency upon request. The oxygen analyzer is to be calibrated annually.
- c. The Permit holder shall operate the Babcock & Wilcox coal fired boiler (Company ID - No. 4 Boiler) such that the average operating shall not exceed 88 MMBTU per hour for any calendar day.

Prepared By: D.	Bush
Date Prepared:	4/18/80
District Sign-Of	f: mg